



AFRISO

AFRISO Sp. z o.o.
Szańska, ul. Kościelna 7
42-677 Czekanów
www.afriso.pl

Customer Service Team
Tel. +48 (0) 32 330 33 55
info@afriso.pl

ATV repair kits with thermostatic insert

NOTE!

The product may only be used if you have fully read and understood these operating instructions. The manual is also available on the AFRISO websites in the Internet.

WARNING!



Risk of scalding by hot medium! Before replacing internal components on the installed valve, make sure that the system has cooled down.


ATV repair kits with thermostatic insert may only be installed, commissioned, and dismantled by trained personnel.

Changes and modifications carried out by unauthorised persons may cause danger and are prohibited for safety reasons.

APPLICATION

Used in heating systems. Mounted inside the housing of the ATV temperature valve. They allow replacement of a damaged thermostatic insert or change of the factory rated temperature of the valve without removing it from the system.

SCOPE OF DELIVERY AND MOUNTING



NOTE!

The guiding lug on the mixing element (Fig. 1) should be positioned in the dedicated guide slot inside the valve (Fig. 2). Only this installation method (Fig. 3) ensures proper valve operation.



Fig. 1. Guiding lug on the mixing element



Fig. 2. Guide slot inside the valve



Fig. 3. Correctly mounted kit

WARRANTY

Product guarantee in accordance with the general conditions of sale and delivery.

CUSTOMER SATISFACTION

For AFRISO customer satisfaction is paramount. If you have any questions, suggestions or product problems, please contact us.